

## Sample Information

Sample ID: <b>21602506</b>	Collectors Name: Larry Plew
Address of Source: N/A	Sample Point: N/A
Project Name: Rogue River High School	Source: Dist-A
Received Date: 07/19/2016	Treatment System: None

## Results of Chemical Analysis

Sample Notes: <b>Kitchen Hand Sink</b>		Collection Date: <b>07/19/16 6:42 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/20/16 9:04 am	JNS AC	A

Sample Notes: <b>Teacher's Staff Lounge</b>		Collection Date: <b>07/19/16 7:00 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst ID	Data Flags
Lead	SM 3113 B	0.01	0.0104	mg/L	0.015	07/20/16 9:04 am	JNS AA	A

**DEFINITIONS AND DATA FLAGS**

- |   |  |
|---|--|
| <p>A Analysis is covered under ORELAP scope of Accreditation</p> <p>AA Analysis is covered under ISO scope of Accreditation</p> <p>C Sample did not meet acceptance criteria</p> <p>H Analysis performed outside method hold time</p> <p>ID Subsample identifier for each Sample number</p> <p>M Matrix Spike recovery is out of control limits due to matrix interference<br/>The LCS was in acceptance limits showing the analysis is in control and the data is acceptable</p> | <p>E Estimated Value</p> <p>LOQ Reporting Limit</p> <p>N/A Not Applicable</p> <p>ND None Detected</p> <p>S Sample Outsourced</p> |
|---|--|

Results Color Key	
White - No EPA Limit	
Low Risk within EPA Limit	
Medium Risk	
High Risk Exceeds EPA Limit	
Call the Lab to Discuss	



# Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · [www.gpwaterlab.com](http://www.gpwaterlab.com)

**Mail To:**

**Rogue River School District 35**

Attn: Larry Plew

P.O. Box 1045

Rogue River, OR 97537

Date:

July 20, 2016

Address of Source:

N/A

Sample ID #:

21602506

Project Name:

Rogue River High School

## Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark  
Senior Chemist

## Sample Information

Sample ID: <b>21602324</b>	Collectors Name: Larry Plew
Address of Source: Rogue River Elem School East Campus	Sample Point: N/A
Project Name: RRSD 35 - Elem East	Source: Dist-A
Received Date: 07/07/2016	Treatment System: None

## Results of Chemical Analysis

Sample Notes: <b>RRES East 1st Outside Drmk Ftn</b>		Collection Date: <b>07/06/16 6:48 AM</b>								
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Copper	EPA 200.7	0.006	ND	mg/L	1.3	07/08/16 2:17 pm	JNS	AE	A	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AJ	A	
Sample Notes: <b>RRES East Campus Rm 8</b>		Collection Date: <b>07/06/16 6:50 AM</b>								
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Copper	EPA 200.7	0.006	0.0063	mg/L	1.3	07/08/16 2:17 pm	JNS	AA	A	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AF	A	
Sample Notes: <b>RRES East Boys Bath Rm 1st Sink</b>		Collection Date: <b>07/06/16 6:51 AM</b>								
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Copper	EPA 200.7	0.006	0.0219	mg/L	1.3	07/08/16 2:17 pm	JNS	AD	A	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AI	A	
Sample Notes: <b>RRES East Campus Kitchen</b>		Collection Date: <b>07/06/16 6:52 AM</b>								
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Copper	EPA 200.7	0.006	0.0088	mg/L	1.3	07/08/16 2:17 pm	JNS	AB	A	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AG	A	
Sample Notes: <b>RRES East Campus Room 16</b>		Collection Date: <b>07/06/16 6:53 AM</b>								
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Copper	EPA 200.7	0.006	0.0119	mg/L	1.3	07/08/16 2:17 pm	JNS	AC	A	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AH	A	

**DEFINITIONS AND DATA FLAGS**

A Analysis is covered under ORELAP scope of Accreditation  
 AA Analysis is covered under ISO scope of Accreditation  
 C Sample did not meet acceptance criteria  
 H Analysis performed outside method hold time  
 ID Subsample identifier for each Sample number  
 M Matrix Spike recovery is out of control limits due to matrix interference  
 The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

E Estimated Value  
 LOQ Reporting Limit  
 N/A Not Applicable  
 ND None Detected  
 S Sample Outsourced

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss



# Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · [www.gpwaterlab.com](http://www.gpwaterlab.com)

**Mail To:**

**Rogue River School District 35**

Attn: Larry Plew  
P.O. Box 1045  
Rogue River, OR 97537

Date: July 13, 2016  
Address of Source: Rogue River Elem School  
East Campus  
Sample ID #: 21602324  
Project Name: RRSD 35 - Elem East

## Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark  
Senior Chemist

# Sample Information

Sample ID:	21602322	Collectors Name:	Larry Plew
Address of Source:	Rogue River High School	Sample Point:	N/A
Project Name:	RRSD 35 HS	Source:	Dist-A
Received Date:	07/07/2016	Treatment System:	None

## Results of Chemical Analysis

Sample Notes:		RRHS Custodian Sink		Collection Date:		07/06/16 6:58 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0062	mg/L	1.3	07/08/16 2:17 pm	JNS	AA	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AF	A
Sample Notes:		RRHS Kitchen Hand Sink		Collection Date:		07/06/16 6:59 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0177	mg/L	1.3	07/08/16 2:17 pm	JNS	AB	A
Lead	SM 3113 B	0.01	0.0185	mg/L	0.015	07/08/16 9:04 am	JNS	AG	A
Sample Notes:		RRHS Main Drinking Fountain		Collection Date:		07/06/16 7:00 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.1147	mg/L	1.3	07/08/16 2:17 pm	JNS	AC	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AH	A
Sample Notes:		RRHS Staff Lounge Sink		Collection Date:		07/06/16 7:10 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	ND	mg/L	1.3	07/08/16 2:17 pm	JNS	AD	A
Lead	SM 3113 B	0.01	0.0131	mg/L	0.015	07/08/16 9:04 am	JNS	AI	A
Sample Notes:		RRHS Rm 38 1st Sink on L		Collection Date:		07/06/16 7:30 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.1895	mg/L	1.3	07/08/16 2:17 pm	JNS	AE	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AJ	A

**DEFINITIONS AND DATA FLAGS**

<p>A Analysis is covered under ORELAP scope of Accreditation</p> <p>AA Analysis is covered under ISO scope of Accreditation</p> <p>C Sample did not meet acceptance criteria</p> <p>H Analysis performed outside method hold time</p> <p>ID Subsample identifier for each Sample number</p> <p>M Matrix Spike recovery is out of control limits due to matrix interference The LCS was in acceptance limits showing the analysis is in control and the data is acceptable</p>	<p>E Estimated Value</p> <p>LOQ Reporting Limit</p> <p>N/A Not Applicable</p> <p>ND None Detected</p> <p>S Sample Outsourced</p>
---	--

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss



# Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · [www.gpwaterlab.com](http://www.gpwaterlab.com)

**Mail To:**

**Rogue River School District 35**

Attn: Larry Plew

P.O. Box 1045

Rogue River, OR 97537

Date:

July 13, 2016

Address of Source:

Rogue River High School

Sample ID #:

21602322

Project Name:

RRSD 35 HS

## Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark  
Senior Chemist

## Sample Information

Sample ID: <b>21602325</b>	Collectors Name: Larry Plew
Address of Source: Rogue River Elem School West Campus	Sample Point: N/A
Project Name: RRSD 35 - Elem West	Source: Dist-A
Received Date: 07/07/2016	Treatment System: None

## Results of Chemical Analysis

Sample Notes: <b>RRES West Main Entry Drnk Ftn</b>			Collection Date: <b>07/06/16 6:39 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.7407	mg/L	1.3	07/08/16 2:17 pm	JNS	AB	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AG	A
Sample Notes: <b>RRES West Boys Lkr Rm Drnk Ftn</b>			Collection Date: <b>07/06/16 6:40 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.2994	mg/L	1.3	07/08/16 2:17 pm	JNS	AC	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AH	A
Sample Notes: <b>RRES West Library Sink</b>			Collection Date: <b>07/06/16 6:43 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0313	mg/L	1.3	07/08/16 2:17 pm	JNS	AD	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AI	A
Sample Notes: <b>RRES West 6th Wing Drnk Ftn</b>			Collection Date: <b>07/06/16 6:45 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.2893	mg/L	1.3	07/08/16 2:17 pm	JNS	AE	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AJ	A
Sample Notes: <b>RRES West Rm 18 Back Sink</b>			Collection Date: <b>07/06/16 6:45 AM</b>						
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0407	mg/L	1.3	07/08/16 2:17 pm	JNS	AA	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AF	A

### DEFINITIONS AND DATA FLAGS

A Analysis is covered under ORELAP scope of Accreditation  
 AA Analysis is covered under ISO scope of Accreditation  
 C Sample did not meet acceptance criteria  
 H Analysis performed outside method hold time  
 ID Subsample identifier for each Sample number  
 M Matrix Spike recovery is out of control limits due to matrix interference  
 The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

E Estimated Value  
 LOQ Reporting Limit  
 N/A Not Applicable  
 ND None Detected  
 S Sample Outsourced

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss



# Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · [www.gpwaterlab.com](http://www.gpwaterlab.com)

**Mail To:**

**Rogue River School District 35**

Attn: Larry Plew  
P.O. Box 1045  
Rogue River, OR 97537

Date: July 13, 2016  
Address of Source: Rogue River Elem School  
West Campus  
Sample ID #: 21602325  
Project Name: RRSD 35 - Elem West

## Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark  
Senior Chemist